

Certificate of Compliance

Certificate:

220331

Project:

1430364

Date Issued: May 14, 2003

Issued to:

Mettler-Toledo GmbH

Im Hackacker 15 **Urdorf, 8902 SWITZERLAND**

Attention:

Mr. Alfred Peer

The products listed below are eligible to bear the CSA Mark shown



Issued by:

Pocholo Laforteza

Authorized by: Nick Alfano

Operations Manager

PRODUCTS

Class 2258 02 PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Division 2, Groups A, B, C and D Ex nA IIC T4

2100e pH Transmitter, 5100e CO2 Transmitter, 4100e O2 Transmitter, 7100e Cond Transmitter, 7100e Cond Ind Transmitter and 4100ppb Oxy (trace elements) Transmitter, conduit connected, rated Input 24-230V ac/dc -15%/+10%, 45 to 65 Hz, 6VA; four sets of relay contacts 250V ac, 3.0 amps or 120Vdc, 3.0 amps, milliamp outputs rated 0 to 20 mA (with 130Vac/dc isolation), and other signal circuits all SELV including sensor connection which provides non-incendive connections to one of the following sensor type: InPro 3200, 4250, 6800, 6900, CO₂, 7000, 7100 and 7200 using maximum 3.2 metres of cable. (Refer to control drawing 194.130-240). Operating ambient: -20 to 55°C, installation category II, pollution degree 2. Type 2 enclosure. Temperature Code T4.



Certificate: 220331

Project: 1430364 **Date:** May 14, 2003

Conditions for safe use:

1. The equipment shall be installed and protected from mechanical impact and ultraviolet (UV) sources.

- 2. Clean only with a moistened antistatic cloth as potential electrostatic hazard may exist. Service equipment only with conductive clothing, footwear and personal grounding devices to prevent electrostatic accumulation.
- 3. Internal grounding provisions shall be provided for field wiring. Bonding between conduit shall be provided during installation, and all exposed non-current carrying metallic parts shall be bonded and grounded.
- 4. Installation in a Class I, Division 2 or Class I, Zone 2 hazardous locations shall be in accordance with the Canadian Electrical Code C22.1 Section 18 Division 2 wiring methods.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures

CSA Std C22.2 No. 213-M1987 - Non-Incendive Electrical Equipment for Use in Class I, Division

2 Hazardous Locations.

CAN/CSA-C22.2 No. 1010.1-92 - Safety Requirements for Electrical Equipment for Measurement,

Control, and Laboratory Use, Part 1: General Requirements.

CAN/CSA-E60079-15:02 - Electrical Apparatus for Explosive Gas Atmospheres--Part 15:

Electrical Apparatus with Type of Protection "n"

TIL I-29B - Interim Certification Requirements for Process Control Equipment

MARKINGS

- Submittor's identification (company name and/or file number);
- Model designation;
- Electrical rating;
- Date of manufacture (or traceable serial number);
- CSA Mark;
- Hazardous locations designation
- Temperature Code
- Maximum ambient
- Certificate number marked "1342049X"
- Reference to control drawing
- Warning: Substitution of components may impair suitability for hazardous locations
- Warning: Do not disconnect equipment unless power has been switched off.
- Warning: Clean only with antistatic moistened cloth.
- Caution: Use supply wires suitable for 30 °C above surrounding ambient and rated at least 250 V.
- Caution: Use signal wires suitable for at least 250 V.



Supplement to Certificate of Compliance

Certificate:

220331

1430364

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description	
		Submittor – Knick Elektronische (LR 112122)	Listee – Mettler Toledo
1430364	May 14, 2003	Stratos 2402 pH	2100e pH Tansmitter
		Stratos 2402 CO2	5100e CO2 Transmitter
		Stratos 2402 Oxy	4100e O2 Transmitter
		Stratos 2403 Oxy	4100ppb O2 Transmitter
		Stratos 2402 Cond	7100e Cond Transmitter
		Stratos 2402 CondI	7100e Cond Ind Transmitter