

## FB1 - &lt;offline&gt;

"Cyclic\_Operation"


**Name:** Family:  
**Author:** Version: 0.1  
**Block version:** 2  
**Time stamp Code:** 06/24/2015 02:33:38 PM  
**Interface:** 06/22/2015 09:29:15 AM  
**Lengths (block/logic/data):** 01494 01296 00030

Name	Data Type	Address	Initial Value	Comment
IN		0.0		
OUT		0.0		
IN_OUT		0.0		
STAT		0.0		
TMR_CMD_Ack	TON	0.0		
TEMP		0.0		
CMD_Ack_TMR_Done	Bool	0.0		
Return_Val	Int	2.0		

## Block: FB1 Cyclic Operation


This program provides an example of how an IND131/331 Indicator can be used by a PLC to monitor weight, send commands, and do a calibration procedure from the PLC.

## Network: 1 Initialize process on Restart




## Network: 2 Read the Command Status and the Scale Status

Get the Command Status and the Scale Status from the Input buffer. We'll use these registers to validate the data coming in on the next rung. Note that we have to swap the bytes for the Scale Status to get things to line up correctly.




Network: 3 Update the data read from the ProfiBus IND

Only update the data if the Data OK bit is on OR if the Calibration Procedure is in progress, and the Data Integrity bits match (indicating that the data inbetween the bits is valid). Otherwise, throw the data away.




Network: 4 Data OK bit is OFF

If we're not Calibrating AND the Data\_Ok bit is off, indicate an error in the Floating Point value by writing a -9999.0 to it, and also indicate an error in the Data Displayed variable by writing a -1 to it.




Network: 5 Read the Command Acknowledgement status

Grab the two Command Acknowledgement bits out of the status and stuff them into a word (MW10) that we can use in the following rung to determine if a command has been acknowledged.



Network: 6 Handle Command Acknowledged bit

When a Command Ack is detected (CMD\_Ack is NOT Equal to CMD\_Ack\_Hist) the turn on the Command Acked bit and run a timer.



Network: 7 The Command ACK Timer



Network: 8 Command ACK Timer Complete


When the Command Ack timer expires, set the history to the new CMD\_Ack state, which shuts everything off.



Network: 9 Update the Command to the IND

The IND only acts on a command if it sees a change from the previous command. That means if you need to send another Tare after the first Tare, there must be another command between them - such as Display Net Weight.


This rung waits until the command changes, then it writes the Command, and the Command Data to the PLC's output buffer to the IND. It then updates the history.





to read after one of the command bits has been set.

Other commands that can be sent to the Indicator can be found in the PLC Interface Manual.



Network: 13 Calibration Routine Request

If the Calibration routine has been requested, initialize the Calibration step

sequence to zero and then run the procedure.

The procedure will clear the request flag when it is complete.

