

UDT3 - <offline>

"Cal_Status"

Name: **Family:**
Author: **Version:** 0.1
 Block version: 2
Time stamp Code: 06/22/2015 11:22:15 AM
 Interface: 06/22/2015 11:22:15 AM
Lengths (block/logic/data): 00000 00000 00000

Address	Name	Type	Initial value	Comment
0.0		STRUCT		
+0.0	Cal_In_Progress	BOOL	FALSE	
+0.1	Calibration_Success	BOOL	FALSE	
+0.2	Calibration_Failed	BOOL	FALSE	
+0.3	Zero_Timed_Out	BOOL	FALSE	
+0.4	Zero_Motion_Detected	BOOL	FALSE	
+0.5	Zero_Data_OK_not_Off	BOOL	FALSE	The Data_OK bit did not turn OFF during Zero operation.
+0.6	Spare1	BOOL	FALSE	
+0.7	Spare2	BOOL	FALSE	
+1.0	Span1_Timed_Out	BOOL	FALSE	
+1.1	Span1_Motion_Detected	BOOL	FALSE	
+1.2	Span1_Data_OK_not_Off	BOOL	FALSE	The Data_OK bit did not turn OFF during Span operation.
+1.3	Spare3	BOOL	FALSE	
+1.4	Spare4	BOOL	FALSE	
+1.5	Spare5	BOOL	FALSE	
+1.6	Spare6	BOOL	FALSE	
+1.7	Spare7	BOOL	FALSE	
=2.0		END_STRUCT		